# CBE507 LECTURE III Controller Design Using State-space Methods

## **Professor Dae Ryook Yang**

## Fall 2013 Dept. of Chemical and Biological Engineering Korea University

**CBE495 Process Control Application** 

Korea University III-1

#### Overview

#### States

- What characterize a system.
- The internal state variables are the smallest possible subset of system variables that can represent the entire state of the system at any given time.
- State variables must be linearly independent.

#### State-space model

$$\dot{\mathbf{x}} = d\mathbf{x} / dt = \mathbf{f}(\mathbf{x}, \mathbf{u}, \mathbf{d})$$

where 
$$\mathbf{x} = [x_1, \dots, x_n]^T$$
,  $\mathbf{u} = [u_1, \dots, u_m]^T$ ,  $\mathbf{d} = [d_1, \dots, d_l]^T$ 

- x: states
- u: inputs
- d: disturbances
- y: outputs can be a function of above, y=g(x,d,u)
- If higher order derivatives exist, convert them to 1st order

**CBE495 Process Control Application** 

## **Control Law Design**

- Linear state-space model (SISO)
  - Continuous-time version:  $\dot{\mathbf{x}} = \mathbf{F}\mathbf{x} + \mathbf{G}u$

$$y = \mathbf{H}\mathbf{x} + \mathbf{J}u$$

 Discrete-time version:  $\mathbf{x}(k+1) = \mathbf{\Phi}\mathbf{x}(k) + \mathbf{\Gamma}u(k)$ 

$$y(k) = \mathbf{H}\mathbf{x}(k) + \mathbf{J}u(k)$$

where

$$y(k) = \mathbf{H}\mathbf{X}(k) + \mathbf{J}u(k)$$

$$\mathbf{\Phi} = e^{\mathbf{F}\Delta t}, \quad \mathbf{\Gamma} = \int_0^{\Delta t} e^{\mathbf{F}\eta} d\eta \mathbf{G}$$

$$e^{-\mathbf{F}t}\dot{\mathbf{x}} - e^{-\mathbf{F}t}\mathbf{F}\mathbf{x} = e^{-\mathbf{F}t}\mathbf{G}u \Rightarrow \int_t^{t+\Delta t} d(e^{-\mathbf{F}\tau}\mathbf{x}) = \int_t^{t+\Delta t} e^{-\mathbf{F}\tau}\mathbf{G}u d\tau$$

$$e^{-\mathbf{F}t - \mathbf{F}\Delta t}\mathbf{x}(t + \Delta t) - e^{-\mathbf{F}t}\mathbf{x}(t) = \int_t^{t+\Delta t} e^{-\mathbf{F}\tau}u d\tau \mathbf{G}$$

$$\mathbf{x}(t + \Delta t) = e^{\mathbf{F}\Delta t}\mathbf{x}(t) + \int_t^{t+\Delta t} e^{-\mathbf{F}(\tau - t - \Delta t)}u d\tau \mathbf{G} \quad (\eta = \tau - t - \Delta t)$$

## Design steps

- If all the states are available, use state feedback. (u=-Kx)
- If a part of states are available, design a state estimator.
- The state estimator is also called a state observer.

**CBE495 Process Control Application** 

Korea University

## Calculation of $e^{At}$

**Taylor series expansion** 

$$\mathbf{\Phi} = e^{\mathbf{F}t} = \mathbf{I} + \mathbf{F}t + \mathbf{F}^2t^2 / 2! + \mathbf{F}^3t^3 / 3! + \dots = \mathbf{I} + \mathbf{F}t\mathbf{\Psi}$$
where  $\mathbf{\Psi} = \mathbf{I} + \mathbf{F}t / 2! + \mathbf{F}^2t^2 / 3! + \mathbf{F}^3t^3 / 4! + \dots$ 

$$\approx \mathbf{I} + \mathbf{F}t / 2(\mathbf{I} + \mathbf{F}t / 3(\dots \mathbf{F}t / (N - 1)(\mathbf{I} + \mathbf{F}t / N)) \dots)$$

Calculation of  $\Phi$  and  $\Gamma$   $\Phi = e^{F\Delta t} = I + F\Delta t \Psi$ 

$$\mathbf{\Phi} = e^{\mathbf{F}\Delta t} = \mathbf{I} + \mathbf{F}\Delta t \mathbf{\Psi}$$

$$\Gamma = \int_0^{\Delta t} e^{\mathbf{F} \eta} d\eta \mathbf{G} \approx \sum_{k=0}^{\infty} \frac{\mathbf{F}^k \Delta t^{k+1}}{(k+1)!} \mathbf{G} = \sum_{k=0}^{\infty} \frac{\mathbf{F}^k \Delta t^k}{(k+1)!} \Delta t \mathbf{G} = \Psi \Delta t \mathbf{G}$$
• Example (Double integrator)

$$\dot{\mathbf{x}} = \begin{bmatrix} 0 & 1 \\ 0 & 0 \end{bmatrix} \mathbf{x} + \begin{bmatrix} 0 \\ 1 \end{bmatrix} u, \quad y = \begin{bmatrix} 1 & 0 \end{bmatrix} \mathbf{x} \qquad (\mathbf{F}^2 = 0)$$

$$\boldsymbol{\Phi} = e^{\mathbf{F}\Delta t} = \mathbf{I} + \mathbf{F}\Delta t + \mathbf{F}^2 \Delta t^2 / 2! + \dots = \begin{bmatrix} 1 & 0 \\ 0 & 1 \end{bmatrix} + \begin{bmatrix} 0 & 1 \\ 0 & 0 \end{bmatrix} \Delta t = \begin{bmatrix} 1 & \Delta t \\ 0 & 1 \end{bmatrix}$$

$$\boldsymbol{\Gamma} = (\mathbf{I} + \mathbf{F}\Delta t / 2) \Delta t \boldsymbol{G} = \begin{bmatrix} 1 & 0 \\ 0 & 1 \end{bmatrix} \Delta t + \begin{bmatrix} 0 & 1 \\ 0 & 0 \end{bmatrix} \frac{\Delta t^2}{2} \begin{bmatrix} 0 \\ 1 \end{bmatrix} = \begin{bmatrix} \Delta t^2 / 2 \\ \Delta t \end{bmatrix}$$

**CBE495 Process Control Application** 

**Korea University** 

#### State feedback control

$$\mathbf{x}(k+1) = \mathbf{\Phi}\mathbf{x}(k) - \mathbf{\Gamma}\mathbf{K}\mathbf{x}(k) \Rightarrow (z\mathbf{I} - \mathbf{\Phi} + \mathbf{\Gamma}\mathbf{K})\mathbf{X}(z) = 0$$

- Characteristic equation:  $|z\mathbf{I} - \mathbf{\Phi} + \mathbf{\Gamma}\mathbf{K}| = 0$ 

## Pole placement example (Double integrator)

- Desired pole location:  $z=0.8 \pm j0.25$  with  $\Delta t=0.1$ 

$$\left|z\mathbf{I} - \mathbf{\Phi} + \mathbf{\Gamma}\mathbf{K}\right| = \left|z\begin{bmatrix}1 & 0\\ 0 & 1\end{bmatrix} - \begin{bmatrix}1 & \Delta t\\ 0 & 1\end{bmatrix} + \begin{bmatrix}\Delta t^2/2\\ \Delta t\end{bmatrix} \begin{bmatrix}K_1 & K_2\end{bmatrix}\right| = 0$$

$$z^{2} + (\Delta t K_{2} + \Delta t^{2} K_{1}/2 - 2)z + \Delta t^{2} K_{1}/2 - \Delta t K_{2} + 1 = 0$$

Desired char. eqn: 
$$z^2 - 1.6z + 0.7 = 0$$

$$\Delta t K_2 + \Delta t^2 K_1 / 2 - 2 = -1.6$$

$$z + \Delta t^2 K_1 / 2 - \Delta t K_2 + 1 = 0.7$$
  $\Rightarrow K_1 = 10, K_2 = 3.5$ 

**CBE495 Process Control Application** 

Korea University III-5

#### **Control Canonical Form**

## Characteristic polynomial

- 
$$\alpha(z)=z^n+a_1z^{n-1}+\dots a_{n-1}z+a_n$$

$$\mathbf{x}(k+1) = \mathbf{\Phi}_{c}\mathbf{x}(k) + \mathbf{\Gamma}_{c}u(k)$$

$$y(k) = \mathbf{H}_{c}\mathbf{x}(k)$$

• Control Canonical form 
$$\Phi_{c} = \begin{bmatrix} -a_{1} & -a_{2} & & -a_{n} \\ 1 & 0 & 0 & \cdots & 0 \\ 0 & 1 & 0 & \cdots & 0 \\ \vdots & 0 & \ddots & \cdots & \vdots \\ 0 & \cdots & 0 & 1 & 0 \end{bmatrix} \quad \Gamma_{c} = \begin{bmatrix} 1 \\ 0 \\ 0 \\ \vdots \\ 0 \end{bmatrix}$$
 
$$\mathbf{x}(k+1) = \Phi_{c}\mathbf{x}(k) + \Gamma_{c}u(k)$$
 
$$\mathbf{y}(k) = \mathbf{H}_{c}\mathbf{x}(k)$$
 
$$\mathbf{H}_{c} = [b_{1} \quad b_{2} \quad b_{3} \quad \cdots \quad b_{n}]$$

#### State-feedback control

$$\mathbf{x}(k+1) = \mathbf{\Phi}_{c}\mathbf{x}(k) - \mathbf{\Gamma}_{c}\mathbf{K}\mathbf{x}(k) = (\mathbf{\Phi}_{c} - \mathbf{\Gamma}_{c}\mathbf{K})\mathbf{x}(k)$$

$$\mathbf{\Phi}_{c} - \mathbf{\Gamma}_{c}\mathbf{K} = \begin{bmatrix}
-a_{1} - K_{1} & -a_{2} - K_{2} & \cdots & -a_{n} - K_{n} \\
1 & 0 & 0 & \cdots & 0 \\
0 & 1 & 0 & \cdots & 0 \\
\vdots & 0 & \ddots & \cdots & \vdots \\
0 & \cdots & 0 & 1 & 0
\end{bmatrix} \Rightarrow \alpha(z) = z^{n} + (a_{1} + K_{1})z^{2} + \cdots + (a_{n} + K_{n})$$

**CBE495 Process Control Application** 

## · How to convert to canonical form

- It is possible when the system is controllable.
- Controllability
  - The system  $(\Phi, \Gamma)$  is controllable if for every  $n^{\text{th}}$ -order polynomial  $\alpha_c(z)$ , there exists a control low u=-Kx such that the characteristic polynomial of  $(\Phi-\Gamma K)$  is  $\alpha_c(z)$ .
    - The pair (Φ, Γ) is controllable if and only if the rank of C=[Γ ΦΓ Φ<sup>2</sup>Γ ... Φ<sup>n-1</sup>Γ] is n.
  - The system (Φ, Γ) is controllable if for every x<sub>0</sub> and x<sub>1</sub> there is finite N and a sequence of control u<sub>0</sub>, u<sub>1</sub>, ..., u<sub>N</sub> such that if the system has state x<sub>0</sub> at k=0, it is forced to state x<sub>1</sub> at k=N.
  - The system  $(\Phi,\Gamma)$  is controllable if every mode in  $\Phi$  is connected to the control input.

**CBE495 Process Control Application** 

Korea University III-7

## **Controllability Matrix**

• Controllability matrix,  $C=[\Gamma \Phi \Gamma \Phi^2 \Gamma ... \Phi^{N-1}\Gamma]$  should be invertible for system to be controllable.

$$\mathbf{x}(1) = \mathbf{\Phi}\mathbf{x}(0) + \Gamma u(0)$$

$$\mathbf{x}(2) = \mathbf{\Phi}\mathbf{x}(1) + \Gamma u(1) = \mathbf{\Phi}^{2}\mathbf{x}(0) + \mathbf{\Phi}\Gamma u(0) + \Gamma u(1)$$

$$\vdots$$

$$\mathbf{x}(N) = \mathbf{\Phi}^{N}\mathbf{x}(0) + \sum_{j=0}^{N-1} \mathbf{\Phi}^{N-1-j}\Gamma u(j)$$

$$\Rightarrow \left[ \mathbf{\Gamma} \quad \mathbf{\Phi}\Gamma \quad \cdots \quad \mathbf{\Phi}^{N-1}\Gamma \right] \begin{bmatrix} u(N-1) \\ u(N-2) \\ \vdots \\ u(0) \end{bmatrix} = \mathbf{x}(N) - \mathbf{\Phi}^{N}\mathbf{x}(0)$$

#### · Ackermann's formula

 Satisfactory for SISO systems of order less than 10 and can handle systems with repeated roots.

$$\mathbf{K} = \begin{bmatrix} 0 & \cdots & 0 & 1 \end{bmatrix} \begin{bmatrix} \mathbf{\Gamma} & \mathbf{\Phi} \mathbf{\Gamma} & \cdots & \mathbf{\Phi}^{N-1} \mathbf{\Gamma} \end{bmatrix}^{-1} \alpha_c(\mathbf{\Phi})$$

- Selecting the desired characteristic polynomial,  $\alpha_c(z)$  should be based on system evaluations such as step response and etc.

**CBE495 Process Control Application** 

## **Estimator Design**

- If the full states are not available, unmeasured states should be estimated based on the output measurements to use state feedback strategy.
- Model of plant dynamics

$$\overline{\mathbf{x}}(k+1) = \mathbf{\Phi}\overline{\mathbf{x}}(k) + \mathbf{\Gamma}u(k)$$

- The model  $(\Phi, \Gamma)$  and u(k) are known and the estimate of the initial condition  $\mathbf{x}(0)$  is assumed to be obtained.
- The error dynamics:  $\tilde{\mathbf{x}}(k+1) = \mathbf{\Phi}\tilde{\mathbf{x}}(k)$   $(\tilde{\mathbf{x}} = \mathbf{x} \overline{\mathbf{x}})$
- If  $\Phi$  is unstable, the error will not converge to zero.
- Prediction estimator

$$\overline{\mathbf{x}}(k+1) = \mathbf{\Phi}\overline{\mathbf{x}}(k) + \mathbf{\Gamma}u(k) + \mathbf{L}_{p}[y(k) - \mathbf{H}\overline{\mathbf{x}}(k)]$$

$$\Rightarrow \tilde{\mathbf{x}}(k+1) = [\mathbf{\Phi} - \mathbf{L}_{p}\mathbf{H}]\tilde{\mathbf{x}}(k)$$

– By pole placement, the estimator gain,  $\mathbf{L}_p$  can be designed to have desired error dynamics.

**CBE495 Process Control Application** 

Korea University III-9

- Is it possible to find  $\mathbf{L}_p$  for desirable error dynamics?
  - It is possible when the system is observable.
  - Observability
    - The system  $(\Phi, H)$  is observable if for every  $n^{\text{th}}$ -order polynomial  $\alpha_e(z)$ , there exists a estimator gain  $\mathbf{L}_p$  such that the characteristic equation of state error of the estimator is  $\alpha_e(z)$ .
      - The pair (Φ, H) is controllable if and only if the rank of O=[H HΦ HΦ $^2$  ... HΦ $^{n-1}$ ] is n.
    - The system ( $\Phi$ , H) is observable if for any  $x_0$ , there is finite N such that  $x_0$  can be computed from observation  $y_0, y_1, ..., y_{N-1}$ .
    - The system  $(\Phi, H)$  is observable if every dynamic mode in  $\Phi$  is connected to the output y via H.

**CBE495 Process Control Application** 

## **Observability Matrix**

• Observability matrix,  $O=[H; H\Phi; H\Phi^{2}; ...; H\Phi^{N-1}]$ should be invertible for system to be observable.

$$y(0) = \mathbf{H}\mathbf{x}(0)$$

$$y(1) = \mathbf{H}\mathbf{x}(1) = \mathbf{H}\mathbf{\Phi}\mathbf{x}(0)$$

$$\vdots$$

$$y(N-1) = \mathbf{H}\mathbf{\Phi}^{N-1}\mathbf{x}(0)$$

$$\Rightarrow \begin{bmatrix} y(0) \\ y(1) \\ \vdots \\ y(N-1) \end{bmatrix} = \begin{bmatrix} \mathbf{H} \\ \mathbf{H}\mathbf{\Phi} \\ \vdots \\ \mathbf{H}\mathbf{\Phi}^{N-1} \end{bmatrix} \mathbf{x}(0)$$

- The controllability and the observability are dual.
- Ackermann's formula
  - Satisfactory for SISO systems of order less than 10 and can handle systems with repeated roots.

$$\mathbf{L}_{p}^{T} = \begin{bmatrix} 0 & \cdots & 0 & 1 \end{bmatrix} \begin{bmatrix} \mathbf{H}^{T} & \mathbf{\Phi}^{T} \mathbf{H}^{T} & \cdots & (\mathbf{\Phi}^{T})^{(N-1)} \mathbf{H}^{T} \end{bmatrix}^{-1} \alpha_{e}(\mathbf{\Phi}^{T})$$

 $\mathbf{L}_{p}^{T} = \begin{bmatrix} 0 & \cdots & 0 & 1 \end{bmatrix} \begin{bmatrix} \mathbf{H}^{T} & \mathbf{\Phi}^{T} \mathbf{H}^{T} & \cdots & \left(\mathbf{\Phi}^{T}\right)^{(N-1)} \mathbf{H}^{T} \end{bmatrix}^{-1} \alpha_{e}(\mathbf{\Phi}^{T})$ - Selecting the desired characteristic polynomial,  $\alpha_{e}(z)$  should be based on prediction error dynamics.

**CBE495 Process Control Application** 

Korea University III-11

## **Current Estimator**

- The previous form of state estimation of x(k) does not involve current measurement.
- Alternative estimator formulation

$$\begin{split} \hat{\mathbf{x}}(k) &= \mathbf{\Phi} \overline{\mathbf{x}}(k) + \mathbf{\Gamma} u(k) + \mathbf{L}_p[y(k) - \mathbf{H} \overline{\mathbf{x}}(k)] \\ \overline{\mathbf{x}}(k) &= \mathbf{\Phi} \hat{\mathbf{x}}(k-1) + \mathbf{\Gamma} u(k-1) \end{split}$$

- It is impossible to have measurement y(k) and u(k) calculation at the same time.
- However, the calculation of u(k) can be arranged to minimize computational delays by performing all calculations before the sample instant that do not directly depend on y(k)measurement.
- In this case, the observability matrix and the calculation of current estimator gain  $L_c$  should be modified accordingly.

**CBE495 Process Control Application** 

## **Reduced-Order Estimators**

- The direct measurements of states do not need to be estimated.
  - If there is significant noise in measurements, full state estimation can provide smoothing for the measured state and estimation of unmeasured states.
  - Division of states (a: directly measured)

$$\begin{bmatrix} \mathbf{x}_{a}(k+1) \\ \mathbf{x}_{b}(k+1) \end{bmatrix} = \begin{bmatrix} \mathbf{\Phi}_{aa} & \mathbf{\Phi}_{ab} \\ \mathbf{\Phi}_{ba} & \mathbf{\Phi}_{bb} \end{bmatrix} \begin{bmatrix} \mathbf{x}_{a}(k) \\ \mathbf{x}_{b}(k) \end{bmatrix} + \begin{bmatrix} \mathbf{\Gamma}_{a} \\ \mathbf{\Gamma}_{b} \end{bmatrix} u(k)$$

$$y(k) = \begin{bmatrix} I & 0 \end{bmatrix} \begin{bmatrix} \mathbf{x}_{a}(k) \\ \mathbf{x}_{b}(k) \end{bmatrix}$$
Known input
$$\mathbf{x}_{b}(k+1) = \mathbf{\Phi}_{bb} \mathbf{x}_{b}(k) + \begin{bmatrix} \mathbf{\Phi}_{ba} \mathbf{x}_{a}(k) + \mathbf{\Gamma}_{b} u(k) \end{bmatrix}$$

$$\mathbf{x}_{a}(k+1) - \mathbf{\Phi}_{aa} \mathbf{x}_{a}(k) - \mathbf{\Gamma}_{a} u(k) = \mathbf{\Phi}_{ab} \mathbf{x}_{b}(k)$$

$$\hat{\mathbf{x}}_{b}(k+1) = \mathbf{\Phi}_{bb} \hat{\mathbf{x}}_{b}(k) + \mathbf{\Phi}_{ba} \mathbf{x}_{a}(k) + \mathbf{\Gamma}_{b} u(k) + \mathbf{L}_{r} [\mathbf{x}_{a}(k+1) - \mathbf{\Phi}_{aa} \mathbf{x}_{a}(k) - \mathbf{\Gamma}_{a} u(k) - \mathbf{\Phi}_{ab} \hat{\mathbf{x}}_{b}(k) ]$$

$$\hat{\mathbf{x}}_{b}(k+1) = [\mathbf{\Phi}_{bb} - \mathbf{L}_{r}, \mathbf{\Phi}_{ab}] \hat{\mathbf{x}}_{b}(k)$$

**CBE495 Process Control Application** 

Korea University III-13

- Reduced-order estimator gain  $\mathbf{L}_r$  can be selected so that the following characteristics equation have desired roots.

$$\alpha_e(z) = |z\mathbf{I} - \mathbf{\Phi}_{bb} + \mathbf{L}_r \mathbf{\Phi}_{ab}| = 0$$

- Or, use Ackermann's formula

$$\mathbf{L}_{r} = \alpha_{e}(\mathbf{\Phi}_{bb}) \begin{bmatrix} \mathbf{\Phi}_{ab} \\ \mathbf{\Phi}_{ab} \mathbf{\Phi}_{bb} \\ \mathbf{\Phi}_{ab} \mathbf{\Phi}_{bb}^{2} \\ \vdots \\ \mathbf{\Phi}_{ab} \mathbf{\Phi}_{bb}^{n-r} \end{bmatrix}^{-1} \begin{bmatrix} 0 \\ 0 \\ \vdots \\ 0 \\ 1 \end{bmatrix}$$

## **Regulator Design: Combined control law and Estimator**

## The separation principle

- Feedback control based on the estimator  $u(k) = -K\overline{x}(k)$  $\mathbf{x}(k+1) = \mathbf{\Phi}\mathbf{x}(k) - \mathbf{\Gamma}K\overline{\mathbf{x}}(k) = \mathbf{\Phi}\mathbf{x}(k) - \mathbf{\Gamma}\mathbf{K}(\mathbf{x}(k) - \tilde{\mathbf{x}}(k))$
- **Estimator**  $\tilde{\mathbf{x}}(k+1) = [\mathbf{\Phi} \mathbf{L}_{p}\mathbf{H}]\tilde{\mathbf{x}}(k)$
- Combination

$$\begin{bmatrix} \tilde{\mathbf{x}}(k+1) \\ \mathbf{x}(k+1) \end{bmatrix} = \begin{bmatrix} \mathbf{\Phi} - \mathbf{L}_{p} \mathbf{H} & 0 \\ \mathbf{\Gamma} \mathbf{K} & \mathbf{\Phi} - \mathbf{\Gamma} \mathbf{K} \end{bmatrix} \begin{bmatrix} \tilde{\mathbf{x}}(k) \\ \mathbf{x}(k) \end{bmatrix}$$

- Characteristic equation
   α<sub>c</sub>(z)α<sub>e</sub>(z) = |zI Φ + ΓK||zI Φ + L<sub>p</sub>H| = 0
   The characteristic poles of complete system consists of the
- combination of the estimator poles and the control poles
- The estimator and the controller can be designed separately.

**CBE495 Process Control Application** 

Korea University III-15

## **Use of Reference Input**

- So far, the state feedback was focus on driving the states to zero. (Regulator problem)
- How to incorporate set point
  - For a given set point r, find  $N_x$  that defines the desired value of states  $x_r$ .  $(N_x r = x_r)$

$$\mathbf{u} = -\mathbf{K}(\mathbf{x} - \mathbf{x}_r) + \mathbf{u}_{ss} = -\mathbf{K}(\mathbf{x} - \mathbf{N}_x \mathbf{r}) + \mathbf{N}_u \mathbf{r}$$
  
where  $\mathbf{u}_{ss} = \mathbf{N}_u \mathbf{r}$ 

$$\mathbf{x}(k+1) = \mathbf{\Phi}\mathbf{x}(k) + \mathbf{\Gamma}\mathbf{u}(k) \Rightarrow \mathbf{x}_{ss} = \mathbf{\Phi}\mathbf{x}_{ss} + \mathbf{\Gamma}\mathbf{u}_{ss} \Rightarrow (\mathbf{\Phi} - \mathbf{I})\mathbf{x}_{ss} + \mathbf{\Gamma}\mathbf{u}_{ss} = 0$$

- Some system output  $y_r = H_r x$  will follow the desired reference.

$$\mathbf{y}_{r} = \mathbf{H}_{r} \mathbf{X}_{ss} = \mathbf{H}_{r} \mathbf{N}_{x} \mathbf{r} = \mathbf{r} \Rightarrow \mathbf{H}_{r} \mathbf{N}_{x} = \mathbf{I}$$

$$\Rightarrow \begin{bmatrix} \mathbf{\Phi} - \mathbf{I} & \mathbf{\Gamma} \\ \mathbf{H}_{r} & \mathbf{0} \end{bmatrix} \begin{bmatrix} \mathbf{N}_{x} \\ \mathbf{N}_{u} \end{bmatrix} = \begin{bmatrix} \mathbf{0} \\ \mathbf{I} \end{bmatrix} \Rightarrow \begin{bmatrix} \mathbf{N}_{x} \\ \mathbf{N}_{u} \end{bmatrix} = \begin{bmatrix} \mathbf{\Phi} - \mathbf{I} & \mathbf{\Gamma} \\ \mathbf{H}_{r} & \mathbf{0} \end{bmatrix}^{-1} \begin{bmatrix} \mathbf{0} \\ \mathbf{I} \end{bmatrix}$$

**CBE495 Process Control Application** 

## Reference input with estimator

#### State-command structure

- Prediction estimator

$$\begin{aligned} \mathbf{u}(k) &= -\mathbf{K}(\overline{\mathbf{x}}(k) - \mathbf{x}_{r}) + \mathbf{N}_{u}\mathbf{r} = -\mathbf{K}\overline{\mathbf{x}}(k) + \overline{\mathbf{N}}\mathbf{r} \\ \text{where } \overline{\mathbf{N}} &= \mathbf{N}_{u} + \mathbf{K}\mathbf{N}_{x} \\ \begin{bmatrix} \mathbf{x}(k+1) \\ \widetilde{\mathbf{x}}(k+1) \end{bmatrix} &= \begin{bmatrix} \mathbf{\Phi} & -\Gamma\mathbf{K} \\ \mathbf{L}_{p}\mathbf{H} & \mathbf{\Phi} - \Gamma\mathbf{K} - \mathbf{L}_{p}\mathbf{H} \end{bmatrix} \begin{bmatrix} \mathbf{x}(k) \\ \widetilde{\mathbf{x}}(k) \end{bmatrix} + \begin{bmatrix} \Gamma \overline{\mathbf{N}} \\ \Gamma \overline{\mathbf{N}} \end{bmatrix} r(k) + \begin{bmatrix} \Gamma_{1} \\ 0 \end{bmatrix} w(k) \end{aligned}$$

- Current estimator

$$\mathbf{u}(k) = -\mathbf{K}(\hat{\mathbf{x}}(k) - \mathbf{x}_{r}) + \mathbf{N}_{u}\mathbf{r} = -\mathbf{K}\hat{\mathbf{x}}(k) + \mathbf{\bar{N}}\mathbf{r}$$

$$\begin{bmatrix} \mathbf{x}(k+1) \\ \hat{\mathbf{x}}(k+1) \end{bmatrix} = \begin{bmatrix} \mathbf{\Phi} & -\mathbf{\Gamma}\mathbf{K} \\ \mathbf{L}_{c}\mathbf{H}\mathbf{\Phi} & \mathbf{\Phi} - \mathbf{\Gamma}\mathbf{K} - \mathbf{L}_{c}\mathbf{H}\mathbf{\Phi} \end{bmatrix} \begin{bmatrix} \mathbf{x}(k) \\ \hat{\mathbf{x}}(k) \end{bmatrix} + \begin{bmatrix} \mathbf{\Gamma}\bar{\mathbf{N}} \\ \mathbf{\Gamma}\bar{\mathbf{N}} + \mathbf{L}_{c}\mathbf{H}\mathbf{\Gamma}\bar{\mathbf{N}} \end{bmatrix} r(k) + \begin{bmatrix} \mathbf{\Gamma}_{1} \\ \mathbf{L}_{c}\mathbf{H}\mathbf{\Gamma}_{1} \end{bmatrix} w(k)$$

Output error command

$$\begin{split} \overline{\mathbf{x}}(k+1) &= (\mathbf{\Phi} - \mathbf{\Gamma} \mathbf{K} - \mathbf{L}_{p} \mathbf{H}) \overline{\mathbf{x}}(k) + \mathbf{L}_{p}(y(k) - r(k)) \\ \left[ \mathbf{x}(k+1) \right] &= \begin{bmatrix} \mathbf{\Phi} & -\mathbf{\Gamma} \mathbf{K} \\ \mathbf{L}_{p} \mathbf{H} & \mathbf{\Phi} - \mathbf{\Gamma} \mathbf{K} - \mathbf{L}_{p} \mathbf{H} \end{bmatrix} \begin{bmatrix} \mathbf{x}(k) \\ \overline{\mathbf{x}}(k) \end{bmatrix} + \begin{bmatrix} \mathbf{0} \\ -\mathbf{L}_{p} \end{bmatrix} r(k) + \begin{bmatrix} \mathbf{\Gamma}_{1} \\ \mathbf{0} \end{bmatrix} w(k) \end{split}$$

**CBE495 Process Control Application** 

Korea University III-17

## **Integral Control**

## Integral control by state augmentation

- Augment the state with  $x_I$ , the integral error, e=y-r.

$$\begin{aligned} \mathbf{x}(k+1) &= \mathbf{\Phi} \mathbf{x}(k) + \mathbf{\Gamma} u(k) + \mathbf{\Gamma}_1 w(k) \\ y(k) &= \mathbf{H} \mathbf{x}(k) \\ x_I(k+1) &= x_I(k) + e(k) = x_I(k) + \mathbf{H} \mathbf{x}(k) - r(k) \\ &\Rightarrow \begin{bmatrix} x_I(k+1) \\ \mathbf{x}(k+1) \end{bmatrix} = \begin{bmatrix} 1 & \mathbf{H} \\ 0 & \mathbf{\Phi} \end{bmatrix} \begin{bmatrix} x_I(k) \\ \mathbf{x}(k) \end{bmatrix} + \begin{bmatrix} 0 \\ \mathbf{\Gamma} \end{bmatrix} u(k) - \begin{bmatrix} 1 \\ \mathbf{0} \end{bmatrix} r(k) \end{aligned}$$

- Control law

$$\mathbf{u}(k) = -\begin{bmatrix} K_I & \mathbf{K} \end{bmatrix} \begin{bmatrix} x_I(k) \\ \mathbf{x}(k) \end{bmatrix} + \mathbf{K} \mathbf{N}_x r(k)$$

- The integral is replacing the feedforward term,  $N_x$ . Also, it has the additional role of eliminating errors due to w.

**CBE495 Process Control Application** 

### **Disturbance Estimation**

## Disturbance rejection

- An alternative approach to state augmentation is to estimate the disturbance signal in the estimator and then to use that estimate in the control law so as to force the error to zero.
- This approach yields results that are equivalent to integral control when the disturbance is constant.

## Disturbance modeling

- Disturbance other than constant biases can be modeled.

$$\begin{aligned} &\mathbf{x}_{d}(k+1) = \mathbf{\Phi}_{d}\mathbf{x}_{d}(k) \\ &w(k) = \mathbf{H}_{d}\mathbf{x}_{d}(k) \\ &\begin{bmatrix} \mathbf{x}(k+1) \\ \mathbf{x}_{d}(k+1) \end{bmatrix} = \begin{bmatrix} \mathbf{\Phi} & -\mathbf{\Gamma}_{1}\mathbf{H}_{d} \\ \mathbf{0} & \mathbf{\Phi}_{d} \end{bmatrix} \begin{bmatrix} \mathbf{x}(k) \\ \mathbf{x}_{d}(k) \end{bmatrix} + \begin{bmatrix} \mathbf{\Gamma} \\ \mathbf{0} \end{bmatrix} u(k) \\ &y(k) = \begin{bmatrix} \mathbf{H} & \mathbf{0} \end{bmatrix} \begin{bmatrix} \mathbf{x}(k) \\ \mathbf{x}_{d}(k) \end{bmatrix} \end{aligned}$$

**CBE495 Process Control Application** 

Korea University III-19

- All the ideas of state estimation still apply to reconstruct the state consisting x and  $x_d$ , provided the system is observable.
- However, the control gain matrix K is not obtained using the augmented model.
- The augmented system will always be uncontrollable since the disturbance is not influenced by control input by no means.
- The estimation of w will be used in a feedforward control scheme to eliminate its effect on steady-state errors.
- This basic idea works if w is a constant, a sinusoid, or any combination of functions that can be generated by a linear model.
- The only constraint is that the disturbance state  $\mathbf{x}_d$  be observable.

## **Effect of Delays**

## Sensor delay

- Sensor delay  $\text{ System:} \quad \mathbf{x}(k+1) = \mathbf{\Phi}\mathbf{x}(k) + \mathbf{\Gamma}u(k) \Rightarrow \begin{bmatrix} \mathbf{x}(k+1) \\ y_{1d}(k+1) \\ y_{2d}(k+1) \end{bmatrix} = \begin{bmatrix} \mathbf{\Phi} & \mathbf{0} & \mathbf{0} \\ \mathbf{H} & \mathbf{0} & \mathbf{0} \\ \mathbf{0} & 1 & \mathbf{0} \end{bmatrix} \begin{bmatrix} \mathbf{x}(k) \\ y_{1d}(k) \\ y_{2d}(k) \end{bmatrix} + \begin{bmatrix} \mathbf{\Gamma} \\ \mathbf{0} \\ \mathbf{0} \end{bmatrix} u(k)$   $\text{ Delayed output:} \quad y_{1d}(k+1) = y(k)$   $y_{2d}(k+1) = y_{1d}(k)$   $y_{d}(k) = \begin{bmatrix} \mathbf{0} & \mathbf{0} & \mathbf{1} \end{bmatrix} \begin{bmatrix} \mathbf{x}(k) \\ y_{1d}(k) \\ y_{2d}(k) \end{bmatrix}$
- The augmented system matrix will cause problem in calculating gains for current estimator.

## **Actuator delay**

$$\begin{bmatrix} \mathbf{x}(k+1) \\ u_d(k+1) \end{bmatrix} = \begin{bmatrix} \mathbf{\Phi} & \mathbf{\Gamma} \\ 0 & 0 \end{bmatrix} \begin{bmatrix} \mathbf{x}(k) \\ u_d(k) \end{bmatrix} + \begin{bmatrix} 0 \\ 1 \end{bmatrix} u(k) + \begin{bmatrix} \mathbf{\Gamma}_1 \\ 0 \end{bmatrix} w(k)$$

$$y(k) = \begin{bmatrix} 1 & 0 \end{bmatrix} \begin{bmatrix} \mathbf{x}(k) \\ u_d(k) \end{bmatrix}$$

**CBE495 Process Control Application**