

The Viking Gasifier

Outline


- Biomass Gasification Group at DTU
- Two stage gasification
- Viking gasifier
 - Technologies
 - Hurdles on the way
- Results from April 2003
- Conclusions

Biomass Gasification Group

- Thermal conversion of biomass
- 15 years of experience
- 12 Employees
- Externally financed

Two-stage gasification

- x Separated pyrolysis and gasification
- x Partial oxidation of pyrolysis gases
 - No tar in gas nor in waste
 - High efficiency



Viking gasifier at DTU

Commissioned August 2002

Small scale ($75 \text{ kW}_{\text{fuel}}$)

Unattended operation

Engine woodgas operation for
> 1100 hours

Waste: only ash, carbon dust
and water



Key data April 2003

- Thermal input 68 kW
- Fuel: wood chips
- Moisture content 35-45 %
- Gasifier efficiency 93%
- Engine efficiency 32%
- Electric efficiency 27%
- Overall electric eff. 25%
- Tar level <5mg/Nm³
- Dust level <5mg/Nm³




Materials

- Partial oxidation zone: Brick lining
- Metal 700-1100C: MA-253 high temp. steel
- Metal <700C: Stainless steel
- Baghouse filter: Polyethylene

Bag house filter system

- x Particle removal just above water dew point.
- x Filter cleaning by N_2 back flush.
 - Bulk particles and condensate recovered separately.
 - Pressure drop < 100 mmWG
 - Low energy consumption



Gas cleaning performance

× 1200 hours of reliable operation without permanent increase of the pressure drop

.Dust after filter <5 mg/Nm³

.Residual tar condenses on particles, removed with these

→ Tar level in gas drops from 25 to "**no tar**" (<5 mg/Nm³)



Police filter after 1200 hours

Viking condensate quality

Amounts:	2-6 l/h
NH ₃ :	1 g/l
Naphtalene:	<20 µg/l
Other PAH:	<2 µg/l
Smell:	NH ₃
⇒ OK for standard biological surridge plant!	



Viking dust quality from bag house filter

Amounts: 100-600 mg/Nm³
=5-30 g/h

Ash: Approx. 50%

Tar: <5% mass

→Low temperature reburning
in boiler should be possible.



Ash from gasifier

- Unconverted carbon in ash from gasifier: $\approx 30\%$
- Total unconverted carbon:
 - 0.1 wt.% of fuel
 - 0.3 % of energy in fuel



Intake manifold of the engine after 1100 hours on Wood Gas



Experiences

- No problems with brick lining
- Minor deposits of salts and carbonates in the hot gas system
- No corrosion of hot metal parts
- No deposits or corrosion in clean gas system and engine
- Shutdown corrosion in the system with cold uncleaned gas

Hurdles on the way

- Ash removal failed



Hurdles on the way

- Ash removal failed
-> Totally new design



Hurdles on the way

- Ash removal failed
 - > Totally new design
- Condensation in ash
 - > Heat tracing



Hurdles on the way

- Ash removal failed
 - > Totally new design
- Condensation in ash
 - > Heat tracing
- Ceramics failed/smelted
 - > New reactor top using brick lining



Hurdles on the way



- Ash removal failed
 - > Totally new design
- Condensation in ash
 - > Heat tracing
- Ceramics failed/smelted
 - > New reactor using bricks
- Minor hurdles
 - Valves stuck during idle periods
 - Fuel feed blockages
 - Engine ignition system

Results during April 2003

Operation:


- Gasifier
380 hours April
(>1300 hours total)
- Engine
346 hours
(>1100 hours total)







Average dry gas composition		
H ₂	30.5	%
CO	19.6	%
CH ₄	1.2	%
CO ₂	15.4	%
N ₂	33.3	%
LHV	5.6	MJ/N m ³
HHV	6.2	MJ/N m ³
Gas flow	37.1	m ³ /h
(dry, 0°C)		

Gas temperatures in char bed





Conclusions

- Fully automatic unattended operation
- 1300 hours of operation
- 25 % efficiency from biomass to electricity to the grid.
- No tar in the gas
- Good engine performance - no deposits in engine
- Condensate not a waste problem
- Dust can be treated separately
- Absence of tars \Rightarrow simple, cheap gas cleaning system.

Questions?

